

2014

Annual Drinking Water Quality Report

January 2013 - December 2013

PWSI#3005736

City of Skiatook - City of Tulsa

## Osage County R.W.D. #15

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the quality water and services delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Drinking water is purchased from the City of Skiatook and the City of Tulsa their Annual Drinking Water Quality Reports along with Osage County Rural Water Management District #15 can be found at our website [www.rwd15.com](http://www.rwd15.com).

If you have any questions about this report or concerning your water utility, please contact Johnna Huddleston at 918-396-2552. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at the District's business office located at 14415 N 52<sup>nd</sup> W Ave. in Skiatook, OK.

Osage County R.W.D. #15 routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1, 2013 to December 31, 2013. (Some of our data may be more than one year old because the state allows us to monitor for some contaminants less often than once per year.) All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

### WATER QUALITY DATA TABLE

The table below lists all of the drinking water contaminants we detected for the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)*

*Parts per billion (ppb) or Micrograms per liter (ug/l)*

*Parts per trillion (ppt) or Nanograms per liter (nanograms/l)*

*Parts per quadrillion (ppq) or Picograms per liter (picograms/l)*

*Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

*Millirems per year (mrem/yr)* - measure of radiation absorbed by the body.

*Nephelometric Turbidity Unit (NTU)* - nephelometric turbidity unit is a measure of the clarity of water.

Turbidity in excess of 5 NTU is just noticeable to the average person.

*Action Level (AL)* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level (MCL)* - The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## TEST RESULTS

Contaminant	Violation Y/N	Highest Level Detected	Range Detected	MCL	MCLG	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
TTHM'S (Total Trihalomethanes) (ppb)	YES	106	97	80	n/a	By-product of drinking water disinfection.

What does this mean and what is being done?

If you receive your drinking water from the City of Tulsa connection all water quality standards have been met. If you receive your drinking water from the City of Skiatook connection, water quality standards have not been met.

The City of Skiatook and Osage County Rural Water Management District #15 are working together to meet drinking water standards in the future by implementing upgrades to the City of Skiatook treatment plant.

TTHM's (Total Trihalomethanes)

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increase risk of getting cancer. The violation occurred over a 12 month period of 2013. TTHM'S is still over the running average of 80ppb. Samples are still being taken every three months for monitoring .

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

- \**Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- \**Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or fanning.
- \**Pesticides and herbicides*, which may come from a variety of sources such as agriculture and residential uses.
- \**Radioactive contaminants*, which are naturally occurring.
- \**Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address the improvements.